



Propane

Property	Unit	Test	Value
SP.GR.@60°F		ASTM D2598	to be reported
Propane Content(Vol%)		ASTM D2163	96 min
Ethane Content		ASTM D2163	2 max
Vap.Pressure@100F(psig)		ASTM D1267 or D2598	200 max
Volatile residue: C4 & heavier (vol %)		ASTM D2163(1)	2.5 max
Residual Matter: Resid.on evap.of 100ml(ml)		ASTM D2158	0.05 max
Residual Matter: oil stain observation(ml)		ASTM D2158	Pass(2)
Corrosion Copper Strip		ASTM D1838 or D5453	No.1 Strip
Sulphur Content (WT%)		ASTM D1266	0.04 max
Hydrogen Sulphide		ASTM D2420 or IP103	Negative
Moisture Content		ASTM D2713 or D1744	Pass